

SAFETY AND HEALTH STANDARDS TEMPORARY HEATING EQUIPMENT

Effective Date: 10/14/11	Standard: 16.19	Document Number: KUCSH0057	Rev: 04
--------------------------	-----------------	----------------------------	---------

the heater unit. Cylinder connectors shall be provided with an excess flow valve to minimize flow in the event of a fuel line rupture

- Blower type or radiant heaters shall not be directed towards any LP-Gas container within 25 feet.
- If two or more heaters are located in an un-partitioned area, the fuel supply containers must be separated by at least 25 feet.
- LP-Gas cylinders shall not be refilled inside buildings or structures. Cylinders shall be stored outside of buildings, on a solid surface, away from vehicular traffic.

REFERENCES:

REVISION HISTORY:

MOC#	Description of Change	Prepared By	Date
17387	Scheduled Review and update. Include document retention times and definitions. Also, updated format and Document number added.	KUC Safety and Health Standards Committee	10/11